

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING NO. 3266-0013:003 Page 1 of 1

CATEGORY: Door Operators

LISTEE: Horton Automatics, 4242 Baldwin Blvd., Corpus Christi TX 78405
Contact: *John Cringole (361) 888-5591 Fax (361) 888-6510

DESIGN: Models 5000, 5300, 5400, 5500 and 5800 series pneumatic swing door operators. Refer to listee's data sheets for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model designation and UL label.

APPROVAL: Listed as door operators for installation in exit locations where openings do not require a fire-rated assembly. Authority having jurisdiction should be consulted prior to installation.

NOTE: Formerly 3265-0013:003

*Rev. 06-08-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 8, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager